



Town of Petrolia
Bright's Grove
Water Treatment Plant

2010

Annual Report



TABLE OF CONTENTS

| | | |
|-----------|---|------------|
| 1. | INTRODUCTION..... | 1-1 |
| 1.1 | Background | 1-1 |
| 1.2 | Maintenance Costs..... | 1-1 |
| 1.3 | Terms and Conditions of the Certificate of Approval..... | 1-1 |
| 2. | CERTIFICATIONS | 2-1 |
| 2.1 | Certificates of Approval..... | 2-1 |
| 2.2 | Permit to Take Water | 2-1 |
| 2.3 | Facility Classification | 2-2 |
| 2.4 | Operator Certification | 2-2 |
| 3. | WATER FLOWS | 3-1 |
| 3.1 | Raw Water Flows | 3-1 |
| 3.2 | Treated Water Flows..... | 3-2 |
| 3.3 | WasteWater Flows | 3-3 |
| 4. | CHEMICALS | 4-1 |
| 4.1 | Properties | 4-1 |
| 4.2 | Usage | 4-1 |
| 5. | SAMPLING ANALYTICAL RESULTS | 5-1 |
| 5.1 | Sampling Program | 5-1 |
| 5.2 | Sampling Results | 5-1 |
| 5.2.1 | Introduction..... | 5-1 |
| 5.2.2 | Microbiological..... | 5-1 |
| 5.2.3 | Turbidity/Disinfection | 5-1 |
| 5.2.4 | Distribution Chlorine Residuals | 5-2 |
| 5.2.5 | Wastewater Clarifier Effluent Total Suspended Solids..... | 5-2 |
| 5.2.6 | Other Parameters | 5-3 |
| 6. | COMPLIANCE WITH TERMS AND CONDITIONS OF THE CERTIFICATE OF APPROVAL (COFA) | 6-1 |
| 6.1 | Statement as to Compliance with Terms and Conditions of CofA | 6-1 |
| 6.2 | Measures Taken to Ensure Compliance with Terms and Conditions of CofA..... | 6-1 |
| 7. | NON-COMPLIANCE WITH TERMS AND CONDITIONS OF THE CERTIFICATE OF APPROVAL (COFA) | 7-1 |
| 8. | DECLARATION OF COUNCIL RESOLUTION | 8-1 |



TABLE OF CONTENTS

| | | |
|-----|--------------------------|-----|
| 8.1 | Declaration | 8-1 |
| 8.2 | Council Resolution | 8-2 |
| 9. | REFERENCES | 9-1 |

APPENDICES

| | |
|-------------------|--------------------------|
| Appendix A | Certificates of Approval |
| Appendix B | Permit to Take Water |
| Appendix C | Sampling Program |
| Appendix D | Sampling Results |
| Appendix E | Correspondence |
| Appendix F | Compliance Checklist |

LIST OF TABLES

| | | |
|-----------|--|-----|
| Table 1-1 | Petrolia Water Treatment Plant Maintenance Costs | 1-1 |
| Table 2-1 | Certificates of Approval | 2-1 |
| Table 2-2 | Permit To Take Water (PTTW) | 2-1 |
| Table 2-3 | Facility Classification | 2-2 |
| Table 2-4 | Operator Certification | 2-2 |
| Table 3-1 | Raw Water Flows for 2010 | 3-1 |
| Table 3-2 | Treated Water Flows for 2010 | 3-2 |
| Table 3-3 | Wastewater Flows for 2010 | 3-3 |
| Table 4-1 | Properties of Chemical Feed Systems | 4-1 |
| Table 4-2 | Annual Chemical Usage at Petrolia WTP for 2010 | 4-1 |
| Table 5-1 | Adverse Microbiological Samples ¹ | 5-1 |
| Table 5-2 | Distribution Free Chlorine Residuals | 5-2 |
| Table 5-3 | Wastewater Clarifier Effluent Total Suspended Solids | 5-2 |
| Table 5-4 | Deviations from ODWS and Regulation | 5-3 |
| Table 7-1 | Non-Compliance Items in the Terms and Conditions of the CofA | 7-1 |



1. INTRODUCTION

1.1 BACKGROUND

The Petrolia WTP is located in the City of Sarnia at Bright's Grove, approximately 20 km from the Town of Petrolia. The municipal street address of the plant is 2701 Lakeshore Road.

The Petrolia Water Treatment Plant (WTP) currently supplies potable water to the Town of Petrolia and other service area municipalities including the Township of Enniskillen, Village of Oil Springs and Township of Dawn-Euphemia. The plant also supplies water to portions of Brooke-Alvinston, Sarnia, St. Clair and Plympton-Wyoming. The total population presently served by the Petrolia WTP is reported at 9639.

The Petrolia WTP provides treatment for water drawn from Lake Huron. The main treatment processes in the plant in 2010 were membrane filtration, fluoridation and chlorination. The permitted capacity for the plant to take water from Lake Huron is 15,586 m³/d, although the plant is approved for a treatment capacity of 12,000 m³/d.

This Report is the 2010 Annual Report for the Town of Petrolia Bright's Grove WTP and follows the format presented in Safe Drinking Water Act, O Reg. 170/03.

1.2 MAINTENANCE COSTS

Table 1-1 lists the maintenance costs of the Petrolia Water Treatment Plant.

Table 1-1 Petrolia Water Treatment Plant Maintenance Costs

| Item | Cost (\$) |
|----------------------------------|---------------|
| Equipment repair and maintenance | 61,786 |
| Building Maintenance | 12,852 |
| Grounds maintenance | 4,294 |
| Data radio & SCADA maintenance | 8,281 |
| Intake maintenance | 1,983 |
| Effluent pump maintenance | 4,386 |
| Total | 93,582 |
| | |
| | |
| | |
| | |



SECTION 1 INTRODUCTION

1. Expenses shown are preliminary figures only based on information supplied from Manager of Finance for the Town of Petrolia on December 8, 2010.
2. Lowlift pump VFD repairs were completed @ a cost of \$2939.
3. HACH completed yearly analyser preventive maintenance & calibration @ a cost of \$15666.
4. Marsh completed yearly calibrations @ a cost of \$3200.
5. Siemens completed yearly chlorinator preventive maintenance @ a cost of \$3046.
6. Atlas Copco completed yearly air compressor preventive maintenance @ a cost of \$5206.
7. Harper Detroit Diesel & Albert Generator Service completed generator maintenance @ a cost of \$2103.
8. Bluewater Plumbing completed backflow device yearly preventive maintenance & piping repairs @ a cost of \$1162.
9. W.J. Barnes completed HVAC yearly preventive maintenance @ a cost of \$586.
10. Sentry Fire completed extinguisher yearly maintenance @ a cost of \$421.
11. Bomar completed electrical maintenance @ a cost of \$2999.
12. Wyoming Tree removed an infected Ash tree @ a cost of \$460.



1.3 TERMS AND CONDITIONS OF THE CERTIFICATE OF APPROVAL

Table 1-1 lists the headings of the Terms and Conditions of the CofA.

Table 1-3 Terms and Conditions of the CofA

| Section No. | Heading |
|--------------|--|
| 1 | Facility description |
| 2 | Definitions & information |
| 3.1 to 3.4 | Compliance |
| 3.5 | Build operate & maintain in accordance |
| 3.6 to 3.8 | Interpretation |
| 3.9 to 3.10 | Other legal obligations |
| 3.11 to 3.13 | Adverse effects |
| 3.14 to 3.15 | Change of Owner |
| 4 | Performance |
| 5 | Monitoring & recording |
| 6 | Operations & maintenance |



2. CERTIFICATIONS

This section covers all certifications related to Petrolia WTP and distribution system, including:

- ♦ Certificates of approval;
- ♦ Permits to take water;
- ♦ Facility/distribution system classification; and,
- ♦ Operator classification.

2.1 CERTIFICATES OF APPROVAL

Table 2-1 summarizes the Certificates of Approval (CofA), which can be found in Appendix A.

Table 2-1 Certificates of Approval

| Certificate Type | Certificate Number | Date Issued | Brief Description of Works Approved |
|-----------------------|--------------------|-------------|--|
| Water Treatment Plant | 1195-6R8RX3 | Dec 7, 2006 | Contains several conditions relating to upgrades to plant performance, existing operations, maintenance, monitoring and recording. |
| | | | |

2.2 PERMIT TO TAKE WATER

The Permit to Take Water (PTTW) for the Petrolia WTP is summarized in Table 2-2 and attached in Appendix B.

Table 2-2 Permit To Take Water (PTTW)

| Permit Number | Source | Issued Date | Expiry Date | Permitted Amount of Taking |
|---------------|------------|---------------|----------------|----------------------------|
| 5412-6RNNF5 | Lake Huron | Sept 29, 2007 | April 30, 2013 | 15,586 m3/day |



2.3 FACILITY CLASSIFICATION

Details of Petrolia facility certifications are presented in Table 2-3.

Table 2-3 Facility Classification

| Facility Type | Facility Name | Facility Level | Certificate No. | Date of Issue |
|---------------|------------------------------------|----------------|-----------------|------------------|
| Plant | Petrolia Water Treatment Plant | II | WT #805 | November 9, 2005 |
| Distribution | Petrolia Water Distribution System | II | WD #2908 | November 1994 |

2.4 OPERATOR CERTIFICATION

The Petrolia Water Supply System (PWSS) was operated by the Town of Petrolia & Waterworks Environmental Services Inc. Effective November 15, 2010 Ontario Clean Water Agency became the operating authority for the Petrolia Water Treatment Plant and the main transmission line. Staff members responsible for the water supply and distribution system are licensed operators with their certifications presented in Table 2-4.

Table 2-4 Operator Certification

| Name | Position | Certificate Level | | Certification Number | | Expiry Date | |
|----------------|---------------------|-------------------|---------|----------------------|---------|-------------|----------|
| | | Plant | Dist. | Plant | Dist. | Plant | Dist. |
| Marc Trottier | WTP ORO | IV | III | 656 | 3727 | 10/31/13 | 12/31/11 |
| Wendy Trottier | WTP OIC | III | TOKEN I | 3326 | TOKEN I | 08/31/11 | TOKEN I |
| Mike Young | WTP Operator | III | III | 3977 | 11744 | 01/31/12 | 11/30/12 |
| Sheldon Jones | WTP Operator | I | II | 17844 | 3328 | 02/28/12 | 08/31/11 |
| Mike Weber | WTP Senior Operator | III | III | 12011 | 56617 | 02/12 | 07/11 |
| Jack Brown | WTP Operator | II | II | 62278 | 11041 | 02/13 | 06/13 |
| Troy Simpson | WTP Operator | OIT | OIT | OT66390 | OT66391 | 10/11 | 10/11 |
| Renee Hornick | WTP ORO | 3 | 3 | 4206 | 17076 | 04/11 | 07/11 |



3. WATER FLOWS

This section gives a summary of records made under the permit to take water.

This section also gives a summary and discussion of the quantity of treated water supplied in 2010 compared to the rated capacity specified in the CofA, including monthly average and maximum daily flows.

Finally, this section accounts for the wastewater production from the water treatment process.

3.1 RAW WATER FLOWS

A summary of the daily quantities of water being taken from Lake Huron (i.e., raw water flow rates) are shown in Table 3-1.

The permitted capacity for the plant to take water from Lake Huron is 15,586 m³/d. The raw water supplied to the treatment system should not exceed this value at anytime.

Table 3-1 shows that the highest maximum day demand of 8478 m³/d has not exceeded the flow allowed in the PTTW of 15,586 m³/d.

Table 3-1 Raw Water Flows for 2010

| Date | Total (m ³) | Max. Day (m ³ /d) |
|----------------|-------------------------|------------------------------|
| January | 128333 | 5139 |
| February | 118526 | 5257 |
| March | 129153 | 4773 |
| April | 133078 | 5378 |
| May | 161435 | 7218 |
| June | 158773 | 6862 |
| July | 172793 | 8478 |
| August | 175756 | 7451 |
| September | 156908 | 6915 |
| October | 156192 | 6216 |
| November | 128687 | 5188 |
| December | 139158 | 6758 |
| 2010 Total/Max | 1758792 | 8478 |

3.2



3.3 TREATED WATER FLOWS

The treated water flows for 2010 are shown in Table 3-2.

Table 3-2 shows that the plant's rated capacity of 12000 m³/d has not been exceeded in 2010. The maximum daily flow was 6979 m³ or 58% of rated capacity.

Table 3-2 Treated Water Flows for 2010

| Date | Total(m ³) | Max. Day (m ³ /d) | % Max of Rated Capacity |
|-----------------------|------------------------|---------------------------------|----------------------------|
| January | 112562 | 4147 | 35 |
| February | 103597 | 4294 | 36 |
| March | 113271 | 3854 | 32 |
| April | 117086 | 4297 | 36 |
| May | 142690 | 5921 | 49 |
| June | 140235 | 5593 | 47 |
| July | 154661 | 6979 | 58 |
| August | 155732 | 6163 | 51 |
| September | 137971 | 5696 | 47 |
| October | 136553 | 5053 | 42 |
| November | 112499 | 4148 | 35 |
| December | 122652 | 5383 | 45 |
| 2010 Total/Max | 1549509 | 6979 | 58 |



3.4 WASTEWATER FLOWS

Wastewater is generated from flushing & cleaning the strainers & racks. Table 3-3 shows that wastewater production in any given month reached up to 11% of the raw water flows.

Table 3-3 Wastewater Flows for 2010

| Date | Total Monthly Wastewater Volume (m³) | % Wastewater to Raw Flow |
|------------------------|--|---------------------------------|
| January | 13533 | 11 |
| February | 12893 | 11 |
| March | 13649 | 11 |
| April | 13521 | 10 |
| May | 15487 | 10 |
| June | 15264 | 10 |
| July | 14708 | 9 |
| August | 16265 | 9 |
| September | 15741 | 10 |
| October | 16555 | 11 |
| November | 13932 | 11 |
| December | 13988 | 10 |
| 2010 Total/Max. | 175534 | 10 |



4. CHEMICALS

This section gives a summary of listing treatment chemicals used, including average dosage rates with special reference to any abnormal usage.

4.1 PROPERTIES

Table 4-1 shows the properties of the chemicals used at Petrolia WTP.

Table 4-1 Properties of Chemical Feed Systems

| Chemical | Purpose | Concentration (%) | Specific Gravity (g/mL) | Target Dosage (mg/L) |
|-------------------------|-----------------------|-------------------|-------------------------|----------------------|
| Chlorine gas | ❖ Pre-chlorination | 100 | ❖ - | ❖ 1.3-2.5 mg/L |
| Liquid Polymer | ❖ Wastewater settling | 50 | ❖ 1.10 | ❖ 4-25 mg/L |
| Hydrofluorosilicic acid | ❖ Fluoridation | 25 | ❖ 1.204 | ❖ 0.4 - 0.8 mg/L |
| | | | | |

4.2 USAGE

Table 4-2 summarizes the annual chemical usage and monthly average dosages.

Table 4-2 Annual Chemical Usage at Petrolia WTP for 2010

| Chemical | Volume (L) or Weight (kg) | Range of Monthly Avg. Dosages (mg/L) | Comments of Any Abnormal Usage |
|-------------------------|---------------------------|--------------------------------------|--|
| Chlorine gas | 3124 kg | 1.6 to 2.0 | Varies with raw turbidity |
| Liquid Polymer | 1752 kg | 5.4 to 16.0 | Varies with raw turbidity |
| Hydrofluorosilicic acid | 2578 kg | 0.3 to 0.4 | 0.2 mg/l exists naturally in feedwater |
| | | | |



5. SAMPLING ANALYTICAL RESULTS

5.1 SAMPLING PROGRAM

5.2 SAMPLING RESULTS

5.2.1 Introduction

Appendix D contains the sampling results for 2010, which are summarized in tables.

5.2.2 Microbiological

The bacteriological data in the raw, treated and distribution water supply are shown in Tables D-5 to D-7.

If the treated or distribution water contains more than 500 colonies per mL on a HPC analysis or more than 200 BKG colonies on a total Coliform membrane filter analysis, then the sample is considered adverse. Moreover, if either the treated or distribution water contains *any* total Coliform (TC) or fecal Coliform (FC), then the sample is considered adverse. The corrective action in all cases is to reanalyze and follow the instructions as directed by the Medical Officer of Health.

The heterotrophic plate count (HPC) is an indicator only of the general bacteriological content of the drinking water. High HPC levels are not associated with waterborne disease outbreaks. Proper chlorine disinfection should reduce the HPC levels to less than 10 cfu/mL. HPC levels above 500 cfu/mL although aren't reported as adverse but should be investigated. They aren't a requirement of LCHS (Lambton Community Health Services) & therefore don't result in a boil water advisory.

Out of the 316 samples taken, there was no adverse water sample in 2010 as shown in Table 5-1.

Table 5-1 Adverse Microbiological Samples¹

| Date | Location | Exceedances | Comments |
|------|----------|-------------|----------|
| | | | ❖ |
| | | | |
| | | | |

5.2.3 Turbidity/Disinfection

Raw water turbidity is greatest during the spring run-off and fall turnover when temperatures and flows are low. Based on the online surface scatter turbidity meter data, the raw water turbidity reached as high as 406 NTU, and had an average of 11 NTU.

Filtrate turbidity at Petrolia WTP is measured continuously on the each rack using three separate on-line HACH laser turbidity meters. Grab samples results are recorded on log sheets daily. SCADA captures data every 1 minute. Treated turbidity grab samples ranged from 0.018 to 0.032 with an average of 0.022 NTU.



5.2.4 Distribution Chlorine Residuals

O Reg 170/03 states that a minimum free chlorine residual of 0.2 mg/L or a minimum combined chlorine residual of 1.0 mg/L should be maintained in the water distribution system.

O Reg 170/03 requires and states that the distribution water quality is considered to be adverse if the free chlorine residual is measured to be less than 0.05 mg/L. The corrective action is to restore chlorination immediately and follow the instructions as directed by the Medical Officer of Health.

A statistical analysis of the free chlorine residuals measured in the distribution system is presented in Table 5-2.

Table 5-2 Distribution Free Chlorine Residuals

| Location | Sample Count | Minimum | Maximum | Average |
|---------------------|--------------|---------|---------|---------|
| Distribution System | 312 | 0.49 | 1.80 | 1.19 |

Table 5-2 shows 0 samples being below 0.2 mg/L.

5.2.5 Wastewater Clarifier Effluent Total Suspended Solids

Table 5-3 shows the results of monthly sampling.

Table 5-3 Wastewater Clarifier Effluent Total Suspended Solids

| Location | Sample Count | Minimum | Maximum | Average |
|-------------------------------|--------------|---------|---------|---------|
| Wastewater Clarifier Effluent | 12 | ND | 35 | 18 |



5.2.6 Other Parameters

Table 5-4 lists the deviations or exceedances of the other water samples summarized in Appendix D.

Table 5-4 Deviations from ODWS and Regulation

| Parameter | Location | Limit | Comments |
|---------------------------|--|---------|--|
| Low Distribution Pressure | Transmission line from Mandaumin to Bright's Grove WTP | >20 psi | Severe weather conditions prevented the operator from getting to the Booster station to rectify a communication fault. During this period the pressure in the system may have been below 20 psi. |



SECTION 6
COMPLIANCE WITH TERMS AND CONDITIONS
OF THE CERTIFICATE OF APPROVAL

6. COMPLIANCE WITH TERMS AND CONDITIONS OF THE CERTIFICATE OF APPROVAL (COFA)

This section provides a statement as to compliance with all of the terms and conditions of the Certificate of Approval (CofA), and a detailed description of the measures taken to ensure compliance with the CofA, including any supporting data or other information.

6.1 STATEMENT AS TO COMPLIANCE WITH TERMS AND CONDITIONS OF COFA

Appendix F contains a checklist of the items that was used to determine compliance with the latest CofA. This checklist includes the requirements of all the Terms and Conditions in this Certificate.

6.2 MEASURES TAKEN TO ENSURE COMPLIANCE WITH TERMS AND CONDITIONS OF COFA

See following tables.



SECTION 7
NON-COMPLIANCE WITH TERMS AND CONDITIONS
OF THE CERTIFICATE OF APPROVAL

7. NON-COMPLIANCE WITH TERMS AND CONDITIONS OF THE CERTIFICATE OF APPROVAL (COFA)

This section provides details of any non-compliance in 2010 with the Terms and Conditions of the latest Certificate of Approval (CofA), as well as details of how and when the non-compliance was corrected.

Table 7-1 lists the non-compliance items that were extracted from the shaded items in Table F-1 in **Appendix F**.

Table 7-1 Non-Compliance Items in the Terms and Conditions of the CofA

| | Description | Resolution |
|---|--|--|
| 1 | The record system did not allow the reader to unambiguously identify the person who made the logbook entry. | This has been resolved with a new logbook to and training to the operator. |
| 2 | Plans and drawings are available for the water treatment plant and the booster pumping station but not the elevated tower. | Ongoing. |



SECTION 8
DECLARATION/COUNCIL RESOLUTION

8. DECLARATION OF COUNCIL RESOLUTION

8.1 DECLARATION

| DECLARATION | |
|---|---|
| I, the undersigned, hereby declare that, to the best of my knowledge, the information contained in this report and the information in support of this report is complete and accurate in every way. | |
| Name | Title |
| Marc Trottier | Waterworks Environmental Services Inc |
| 2435 Lisa Crescent Bright's Grove, Ontario N0N 1C0 | Tel: (519) 331-1383 Fax: (519) 869-6679 E-mail: marc@waterworksmw.com |
| January 18, 2011 | |



SECTION 8
DECLARATION/COUNCIL RESOLUTION

8.2 COUNCIL RESOLUTION

Note: The author of this report requests that this report be presented to council & a motion to accept the report is included in the official minutes. Please sign this declaration & return a copy to the WTP ORO.

| COUNCIL RESOLUTION | |
|--|--|
| I, the undersigned, hereby declare that this report has been presented to council. | |
| Name | Title |
| | |
| Address | Contact Numbers |
| Town of Petrolia 411 Greenfield Street Petrolia, Ontario N0N 1R0 | Tel: (519) 882-2350 Fax: (519) 882-3373 |
| Date | Signature |
| | |



9. REFERENCES

- | | |
|-----------|---|
| MOE, 2002 | Ministry of the Environment. 2002. Safe Drinking Water Act. |
| KMK, 2001 | KMK Consultants Limited. February 2001. Petrolia Water Treatment Plant, First Engineers' Report. |
| KMK, 2004 | KMK Consultants Limited. January 2004. Town of Petrolia, Petrolia Water Treatment Plant Design Report. Membrane Filtration Option to Meet Ontario's New Drinking Water Regulations. |
| MOE, 2010 | Ministry of the Environment. 2010. Ontario Drinking Water Systems Regulations. |



APPENDICES

APPENDICES



APPENDIX A

CERTIFICATES OF APPROVAL



APPENDIX B

PERMIT TO TAKE WATER



APPENDIX C

SAMPLING PROGRAM



APPENDIX C

Table C-1 Sampling Protocol

| Parameter | Frequency Required | Additional Frequency | Chemicals Analyzed |
|---|--|--|--------------------------------|
| Raw Water | | | |
| Microbiological | Weekly | - | Table A (excluding HPC or BKG) |
| Turbidity | Continuous | Daily (On-line Reading) | Turbidity |
| pH | Continuous | Daily (Grab sample measurement) | pH |
| Temperature | Continuous | Daily (Grab sample) | Temperature |
| Treated Water | | | |
| Microbiological | Weekly | - | Table A |
| Turbidity | Continuous | Daily (On-line Reading) | Turbidity |
| Chlorine | Continuous | Daily (Grab sample measurement – free and total) | Free Chlorine |
| Volatile Organics | Quarterly | - | Table B |
| Inorganics | Annually | - | Table C |
| Nitrates/Nitrites | Quarterly | - | Nitrates/Nitrites |
| Pesticides & PCB | Quarterly | - | Table D |
| Fluoride | Continuous | Daily (Grab sample measurement) | Fluoride |
| pH | Continuous | Daily (Grab sample measurement) | pH |
| Distribution Water | | | |
| Microbiological | Weekly of 15 Monthly) ¹ (Total | Weekly (Total of 24 Monthly) ¹ | Table A |
| Chlorine | Grab samples simultaneous to microbiological samples | - | Free Chlorine |
| Volatile Organics | Quarterly (THMs at a point reflecting maximum residence time in the distribution system) | - | Only THMs |
| Inorganics | Annually (Lead at a point reflecting maximum residence time in the distribution system) | - | Only Lead |
| Backwash/Wastewater Effluent to Lake Huron | | | |
| Total Suspended Solids | Monthly (Composite) | - | Total Suspended Solids |



APPENDIX C

| Parameter | Frequency Required | Additional Frequency | Chemicals Analyzed |
|--|--------------------|----------------------|--------------------|
| Note: 1. A minimum of 8 samples, plus an additional 1 sample per 1,000 population, shall be taken monthly, with at least 1 sample taken every week. Given a population of 7,000 this equals to a minimum of 15 samples. | | | |

Table C-2 Tables 1 & 2, Schedules 23 & 24 Ontario Drinking Water O.Reg 170/03

| Table 1 - Microbiological | | |
|--|---|--|
| Total Coliforms | <i>Escherichia coli</i> or fecal coliforms | Heterotrophic plate count or total coliform background count by membrane filter analysis. |
| Table 2 Schedule 24 – Volatile Organics | | |
| Benzene Carbon Tetrachloride 1,2-Dichlorobenzene 1,4-Dichlorobenzene 1,2-Dichloroethane | 1,1-Dichloroethylene Dichloromethane Ethylbenzene Monochlorobenzene Tetrachloroethylene | Toluene Trihalomethanes Trichloroethylene Vinyl chloride Xylene |
| Table 2 Schedule 23 – Inorganics | | |
| Arsenic Barium Boron Cadmium Chromium | Copper Fluoride Iron Lead- O.Reg 170/03 (Sched 15.1) Manganese | Mercury Nitrite Nitrate Selenium Uranium |
| Table 2 Schedule 24 – Pesticides and PCBs | | |
| Alachlor Aldicarb Aldrin+Dieldrin Atrazine Azinphos-methyl Bendiocarb Bromoxynil Carbaryl Carbofuran Chlordane(Total) Chlorpyrifos Cyanazine Diazinon Dicamba 2,4-Dichlorophenol | DDT 2,4-D Diclofop-methyl Dimethoate Dinoseb Diquat Diuron Glyphosate Heptachlor+Heptachlor epoxide Lindane(Total) Malathion Methoxychlor Metolachlor Metribuzin | Paraquat Parathion Pentachlorophenol Phorate Picloram PCB Prometryne Simazine Temephos Terbufos 2,3,4,6-Tetrachlorophenol Triallate 2,4,6-Trichlorophenol Trifluralin 2,4,5-T |



APPENDIX D

SAMPLING RESULTS



APPENDIX D

SAMPLING RESULTS

This Appendix contains the following tables:

| Table No. | Title |
|-----------|--|
| D-1 | Legends for Tables F-2 to F-5 |
| D-2 | Results of Analyses of Water |
| D-3 | Semi-Volatile Organics of the Treated Water (MOE Schedule 2) |
| D-4 | Volatile Organics of the Treated Water (MOE Schedule 2) |
| D-5 | Pesticides & Herbicides of the Treated Water (MOE Schedule 2) |
| D-6 | Organochlorinated Pesticides of the Treated Water (MOE Schedule 2) |
| D-7 | Chemical/Physical Characteristics of the Distribution Water |
| D-8 | Raw Water Bacteriological Data (MOE Schedule 1) |
| D-9 | Treated Water Bacteriological Data (MOE Schedule 1) |
| D-10 | Distribution Water Bacteriological Data (MOE Schedule 1) |
| D-11 | Non-Health Related Chemical/Physical Characteristics for the Treated Water |
| | |

Table D-1 Legends for Tables D-2 to D-13

| Legend | Definition |
|---------|--|
| AO | Aesthetic Objective |
| Average | Refers to the Average value measured |
| D | Deteriorating |
| Exceeds | Refers to the number of exceedances detected for the sample period described |
| Maximum | Refers to the maximum value measured |
| Minimum | Refers to the minimum value measured |
| NA | Not Applicable |
| ND | Not Detected |
| NT | Not Tested |
| OG | Operational Guideline |
| S | Safe |
| SC | Samples Collected |
| US | Unsafe |



APPENDIX D

Table D-2 Results of Analyses of Raw Water

| Parameter | Units | Criteria | 2010 | | | | |
|--|---------|----------|------|---------|---------|---------|---------|
| | | | SC | Minimum | Maximum | Average | Exceeds |
| Inorganics | | | | | | | |
| Colour | TCU | | | | | | |
| Conductivity | uohm/cm | | | | | | |
| Alkalinity (Total as CaCO ₃) | mg/L | | | | | | |
| Dissolved Chloride (Cl) | mg/L | | | | | | |
| Nitrite (N) | mg/L | 1 | 4 | ND | ND | ND | |
| Nitrate (N) | mg/L | 10 | 4 | .258 | .394 | .318 | |
| Nitrate + Nitrite | mg/L | 10 | 4 | .258 | .394 | .318 | |

Table D-2 Results of Analyses of Treated Water

| Parameter | Units | Criteria | 2010 | | | | |
|--|---------|----------|------|---------|---------|---------|---------|
| | | | SC | Minimum | Maximum | Average | Exceeds |
| Inorganics | | | | | | | |
| Colour | TCU | | | | | | |
| Conductivity | umho/cm | | | | | | |
| Alkalinity (Total as CaCO ₃) | mg/L | | | | | | |
| Dissolved Chloride (Cl) | mg/L | | | | | | |
| Nitrite (N) | mg/L | 1 | 4 | ND | ND | ND | |
| Nitrate (N) | mg/L | 10 | 4 | 0.254 | 0.918 | 0.491 | |
| Nitrate + Nitrite | mg/L | 10 | 4 | 0.262 | 0.918 | 0.493 | |



APPENDIX D

Table D-3 Semi-Volatile Organics of the Treated Water (MOE Schedule 2)

| Parameter | Units | Criteria | 2010 | | | | |
|--|-------|----------|------|---------|---------|---------|---------|
| | | | SC | Minimum | Maximum | Average | Exceeds |
| Semivolatiles | | | | | | | |
| 2,3,4,6-Tetrachlorophenol | ug/L | 100 | 4 | ND | ND | ND | |
| 2,4,5-Trichlorophenoxy acetic acid (2,4,5-T) | ug/L | 280 | 4 | ND | ND | ND | |
| 2,4,6-Trichlorophenol | ug/L | 5 | 4 | ND | ND | ND | |
| 2,4-Dichlorophenoxy acetic acid(2,4-D) | ug/L | 100 | 4 | ND | ND | ND | |
| 2-4-Dichlorophenol | ug/L | 900 | 4 | ND | ND | ND | |
| Alachlor | ug/L | 5 | 4 | ND | ND | ND | |
| Aldicarb | ug/L | 9 | 4 | ND | ND | ND | |
| Atrazine | ug/L | 2.5 | 4 | .01 | .01 | .01 | |
| Desethyl-atrazine | ug/L | 2.5 | 4 | .01 | .01 | .01 | |
| Atrazine + Desethyl-atrazine | ug/L | 5 | 4 | .01 | .03 | .02 | |
| Bendiocarb | ug/L | 40 | 4 | ND | ND | ND | |
| Bromoxynil | ug/L | 5 | 4 | ND | ND | ND | |
| Carbaryl | ug/L | 90 | 4 | ND | ND | ND | |
| Carbofuran | ug/L | 90 | 4 | ND | ND | ND | |
| Chlorpyrifos | ug/L | 90 | 4 | ND | ND | ND | |
| Cyanazine | ug/L | 10 | 4 | ND | ND | ND | |
| Diazinon | ug/L | 20 | 4 | ND | ND | ND | |
| Dicamba | ug/L | 120 | 4 | ND | ND | ND | |
| Diclofop-methyl | ug/L | 9 | 4 | ND | ND | ND | |
| Dimethoate | ug/L | 20 | 4 | ND | ND | ND | |
| Dinoseb | ug/L | 10 | 4 | ND | ND | ND | |
| Malathion | ug/L | 190 | 4 | ND | ND | ND | |
| Metolachlor | ug/L | 50 | 4 | ND | ND | ND | |
| Metribuzin | ug/L | 80 | 4 | ND | ND | ND | |
| Ethyl Parathion | ug/L | 50 | 4 | ND | ND | ND | |
| Pentachlorophenol | ug/L | 60 | 4 | ND | ND | ND | |
| Phorate | ug/L | 2 | 4 | ND | ND | ND | |



APPENDIX D

| Parameter | Units | Criteria | 2010 | | | | |
|----------------|-------|----------|------|---------|---------|---------|---------|
| | | | SC | Minimum | Maximum | Average | Exceeds |
| Picloram | ug/L | 190 | 4 | ND | ND | ND | |
| Prometryne | ug/L | 1 | 4 | ND | ND | ND | |
| Simazine | ug/L | 10 | 4 | ND | ND | ND | |
| Terbufos | ug/L | 1 | 4 | ND | ND | ND | |
| Triallate | ug/L | 230 | 4 | ND | ND | ND | |
| Trifluralin | ug/L | 45 | 4 | ND | ND | ND | |
| Benzo(a)pyrene | ug/L | 0.01 | 4 | ND | ND | ND | |

Table D-4 Volatile Organics of the Treated Water (MOE Schedule 2)

| Parameter | Units | Criteria | 2010 | | | | |
|--|-------|----------|------|---------|---------|---------|---------|
| | | | SC | Minimum | Maximum | Average | Exceeds |
| Volatiles | | | | | | | |
| 1,1-Dichloroethylene (vinylidene chloride) | ug/L | 14 | 4 | ND | ND | ND | |
| 1,2-Dichlorobenzene | ug/L | 200 | 4 | ND | ND | ND | |
| 1,2-Dichloroethane | ug/L | 5 | 4 | ND | ND | ND | |
| 1,4-Dichlorobenzene | ug/L | 5 | 4 | ND | ND | ND | |
| Benzene | ug/L | 5 | 4 | ND | ND | ND | |
| Bromodichloromethane | ug/L | | 4 | 2.5 | 4.4 | 3.175 | |
| Bromoform | ug/L | | 4 | ND | ND | ND | |
| Carbon Tetrachloride | ug/L | 5 | 4 | ND | ND | ND | |
| Chlorobenzene | ug/L | 80 | 4 | ND | ND | ND | |
| Chloroform | ug/L | | 4 | 3.1 | 8 | 5.7 | |
| Dibromochloromethane | ug/L | | 4 | 1.5 | 2.3 | 1.95 | |
| Methylene Chloride | ug/L | 50 | 4 | ND | ND | ND | |
| Tetrachloroethylene | ug/L | 30 | 4 | ND | ND | ND | |
| Toluene | ug/L | | 4 | ND | ND | ND | |
| Trichloroethylene | ug/L | 50 | 4 | ND | ND | ND | |
| Vinyl Chloride | ug/L | 2 | 4 | ND | ND | ND | |
| Total Trihalomethanes | ug/L | 100 | 4 | 7.3 | 14 | 9.85 | |



APPENDIX D

Table D-5 Pesticides & Herbicides of the Treated Water (MOE Schedule 2)

| Parameter | Units | Criteria | 2010 | | | | |
|-------------------------------------|-------|----------|------|---------|---------|---------|---------|
| | | | SC | Minimum | Maximum | Average | Exceeds |
| Semivolatiles | | | | | | | |
| Temephos | ug/L | 280 | 4 | ND | ND | ND | |
| Herbicides | | | | | | | |
| Diquat | ug/L | 70 | 4 | ND | ND | ND | |
| Glyphosate | ug/L | 280 | 4 | ND | ND | ND | |
| Paraquat | ug/L | 10 | 4 | ND | ND | ND | |
| NP Pesticides/Herbicides | | | | | | | |
| Diuron | ug/L | 150 | 4 | ND | ND | ND | |
| Guthion | ug/L | 20 | 4 | ND | ND | ND | |



APPENDIX D

Table D-6- Organochlorinated Pesticides of the Treated Water (MOE Schedule 2)

| Parameter | Units | Criteria | 2010 | | | | |
|---------------------------------|-------|----------|------|---------|---------|---------|---------|
| | | | SC | Minimum | Maximum | Average | Exceeds |
| OC Pesticides | | | | | | | |
| a-Chlordane | ug/L | 1 | 4 | ND | ND | ND | |
| Aldrin | ug/L | 0.2 | 4 | ND | ND | ND | |
| Aldrin + Dieldrin | ug/L | 0.7 | 4 | ND | ND | ND | |
| Chlordane (total) | ug/L | 7 | 4 | ND | ND | ND | |
| DDT + Metabolites | ug/L | 30 | 4 | ND | ND | ND | |
| Dieldrin | ug/L | 0.5 | 4 | ND | ND | ND | |
| g-Chlordane | ug/L | 2 | 4 | ND | ND | ND | |
| Heptachlor | ug/L | 1 | 4 | ND | ND | ND | |
| Heptachlor + Heptachlor epoxide | ug/L | 3 | 4 | ND | ND | ND | |
| Heptachlor epoxide | ug/L | 2 | 4 | ND | ND | ND | |
| Lindane | ug/L | 4 | 4 | ND | ND | ND | |
| Methoxychlor | ug/L | 900 | 4 | ND | ND | ND | |
| o,p-DDT | ug/L | 5 | 4 | ND | ND | ND | |
| Oxychlordane | ug/L | 4 | 4 | ND | ND | ND | |
| p,p-DDD | ug/L | 15 | 4 | ND | ND | ND | |
| p,p-DDE | ug/L | 5 | 4 | ND | ND | ND | |
| p,p-DDT | ug/L | 5 | 4 | ND | ND | ND | |
| PCBs | | | | | | | |
| Aroclor 1016 | ug/L | - | 4 | ND | ND | ND | |
| Aroclor 1221 | ug/L | - | 4 | ND | ND | ND | |
| Aroclor 1232 | ug/L | - | 4 | ND | ND | ND | |
| Aroclor 1242 | ug/L | - | 4 | ND | ND | ND | |
| Aroclor 1248 | ug/L | - | 4 | ND | ND | ND | |
| Aroclor 1254 | ug/L | - | 4 | ND | ND | ND | |
| Aroclor 1260 | ug/L | - | 4 | ND | ND | ND | |
| Total PCB | ug/L | 3 | 4 | ND | ND | ND | |



APPENDIX D

Table D-7 Chemical/Physical Characteristics of the Distribution Water

| Parameter | Units | Criteria | 2010 | | | | |
|-----------------|-------|-----------|------|---------|---------|---------|---------|
| | | | SC | Minimum | Maximum | Average | Exceeds |
| Lead | ug/L | 10 | | | | | |
| Trihalomethanes | ug/L | 100 (MAC) | 4 | 7.3 | 14 | 9.8 | |

Table D-8 Raw Water Bacteriological Data

| 2010 Year | Total Coliform (org/100 mL) | | | | | Fecal Coliform/ <i>Escherichia coli</i> (org/100 mL) | | | | |
|--------------|--------------------------------|-----------|-----------|----------|----------|---|-----------|----------|----------|----------|
| | SC | 0 | < 200 | > 200 | > 300 | SC | 0 | < 200 | > 200 | > 300 |
| January | 4 | 4 | 0 | 0 | 0 | 4 | 4 | 0 | 0 | 0 |
| February | 4 | 3 | 1 | 0 | 0 | 4 | 4 | 0 | 0 | 0 |
| March | 5 | 1 | 4 | 0 | 0 | 5 | 5 | 0 | 0 | 0 |
| April | 4 | 1 | 3 | 0 | 0 | 4 | 4 | 0 | 0 | 0 |
| May | 5 | 4 | 1 | 0 | 0 | 5 | 5 | 0 | 0 | 0 |
| June | 4 | 3 | 1 | 0 | 0 | 4 | 3 | 1 | 0 | 0 |
| July | 4 | 4 | 0 | 0 | 0 | 4 | 4 | 0 | 0 | 0 |
| August | 5 | 3 | 2 | 0 | 0 | 5 | 3 | 2 | 0 | 0 |
| September | 4 | 3 | 1 | 0 | 0 | 4 | 3 | 1 | 0 | 0 |
| October | 4 | 3 | 1 | 0 | 0 | 4 | 4 | 0 | 0 | 0 |
| November | 5 | 2 | 3 | 0 | 0 | 5 | 2 | 3 | 0 | 0 |
| December | 4 | 2 | 2 | 0 | 0 | 4 | 4 | 0 | 0 | 0 |
| TOTAL | 52 | 33 | 19 | 0 | 0 | 52 | 45 | 7 | 0 | 0 |



APPENDIX D

Table D-9 Treated Water Bacteriological Data

| 2010 Year | Total Colliform | | | Fecal Colliform/ <i>Escherichia coli</i> | | | HPC or BKG | | | |
|--------------|-----------------|-----------|----------|---|-----------|----------|------------|-----------|----------|----------|
| | SC | S | US | SC | S | US | SC | S | US | D |
| January | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 4 | 0 | 0 |
| February | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 4 | 0 | 0 |
| March | 5 | 5 | 0 | 5 | 5 | 0 | 5 | 5 | 0 | 0 |
| April | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 4 | 0 | 0 |
| May | 5 | 5 | 0 | 5 | 5 | 0 | 5 | 5 | 0 | 0 |
| June | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 4 | 0 | 0 |
| July | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 4 | 0 | 0 |
| August | 5 | 5 | 0 | 5 | 5 | 0 | 5 | 5 | 0 | 0 |
| September | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 4 | 0 | 0 |
| October | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 4 | 0 | 0 |
| November | 5 | 5 | 0 | 5 | 5 | 0 | 5 | 5 | 0 | 0 |
| December | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 4 | 0 | 0 |
| TOTAL | 52 | 52 | 0 | 52 | 52 | 0 | 52 | 52 | 0 | 0 |
| Notes: | | | | | | | | | | |



APPENDIX D

Table D-10 Distribution Water Bacteriological Data

| 2010 Year | Total Coliform | | | Fecal Coliform/ <i>Escherichia coli</i> | | | HPC or BKG | | | |
|--------------|----------------|------------|----------|--|------------|----------|------------|------------|----------|----------|
| | SC | S | US | SC | S | US | SC | S | US | D |
| January | 20 | 20 | 0 | 20 | 20 | 0 | 20 | 20 | 0 | 0 |
| February | 20 | 20 | 0 | 20 | 20 | 0 | 20 | 20 | 0 | 0 |
| March | 25 | 25 | 0 | 25 | 25 | 0 | 25 | 25 | 0 | 0 |
| April | 20 | 20 | 0 | 20 | 20 | 0 | 20 | 20 | 0 | 0 |
| May | 25 | 25 | 0 | 25 | 25 | 0 | 25 | 25 | 0 | 0 |
| June | 20 | 20 | 0 | 20 | 20 | 0 | 20 | 20 | 0 | 0 |
| July | 20 | 20 | 0 | 20 | 20 | 0 | 20 | 20 | 0 | 0 |
| August | 25 | 25 | 0 | 25 | 25 | 0 | 25 | 25 | 0 | 0 |
| September | 20 | 20 | 0 | 20 | 20 | 0 | 20 | 20 | 0 | 0 |
| October | 20 | 20 | 0 | 20 | 20 | 0 | 20 | 20 | 0 | 0 |
| November | 25 | 25 | 0 | 25 | 25 | 0 | 25 | 25 | 0 | 0 |
| December | 20 | 20 | 0 | 20 | 20 | 0 | 20 | 20 | 0 | 0 |
| TOTAL | 260 | 260 | 0 | 260 | 260 | 0 | 260 | 260 | 0 | 0 |
| Notes: | | | | | | | | | | |



APPENDIX D

Table D-11 Non-Health Related Chemical/Physical Characteristics for the Treated Water

| Parameter | ODWS (mg/L unless noted) | 2010 | | | | |
|------------------------------------|--------------------------|------|---------|---------|---------|-------------|
| | | SC | Minimum | Maximum | Average | Exceedances |
| Alkalinity (as CaCO ₃) | 30-500 (OG) | 1 | 72 | 72 | 72 | |
| Copper (ug/l) | ---- | | | | | |
| Iron (ug/l) | ---- | | | | | |
| Free Cyanide | 0.2 | | | | | |
| Manganese (ug/l) | 0.05 (AO) | | | | | |
| pH | 6.5-8.5 (OG) | 365 | 7.28 | 7.99 | 7.77 | |
| Sodium (ug/l) | 20000 (OG) | | | | | |
| Temperature | 15 (OG) | 365 | 1 | 22 | 11 | |
| Toluene (ug/l) | ---- | | | | | |



APPENDIX D



APPENDIX E

CORRESPONDENCE



APPENDIX F

COMPLIANCE CHECKLIST



APPENDIX F

Table F-1 Terms and Conditions of the C of A

| CofA No. | Description | Findings |
|----------------------|---|---|
| FACILITY DESCRIPTION | | |
| 1 | Has any of the description changed? | No |
| GENERAL | | |
| 3.1 | Has Owner followed SDWA & Regs | No – Reg 128/04 logbook entry |
| 3.1 | Has the WTP operating authority of record followed SDWA & Regs? | Yes |
| 3.12 | All reasonable steps taken to minimize or eliminate adverse effects to the environment? | Yes |
| 3.14 | Has Owner notified the MOE Director of any change of ORO or operating authority? | Yes |
| 3.2 | The Owner is severely liable to comply with all conditions of the C of A. | Owner complied with conditions of C of A or SDWA. |
| 3.3 | Any person authorized to carry out work or operate drinking water system has been informed of SDWA & Regs. | Yes |
| 3.4 | Copy of C of A available for reference by all persons responsible for the operation of drinking water system? | Yes |
| 3.5 | Drinking water system designed, developed, built, operated & maintained in accordance with part 1 of C of A & schedule A? | Yes |
| 3.12 | All reasonable steps taken to minimize or eliminate adverse effects to the environment? | Yes |
| 3.18 | Records maintained for at least 5 years? | Yes |
| PERFORMANCE | | |
| 4.1 | System shall not be operated to exceed the rated capacity: 12000 m3/day with 3 membrane trains & 76 modules/train | No exceedances |
| 4.2 | Exceedances under emergency conditions? | No |



APPENDIX F

| CofA No. | Description | Findings |
|-------------------------------------|---|--|
| 4.4 | Annual average concentration of suspended solids in the effluent discharged from the backwash wastewater facility not to exceed 25 mg/l. | Average below 25 mg/l SS. |
| | | |
| | | |
| MONITORING & RECORDING | | |
| 5.1 | Sufficient number of flow measuring devices to permit continuous measurement & recording of flows? | Yes |
| 5.2 | Records maintained where measured flow rate exceeds the maximum flow rate for drinking water system? | No exceedances |
| 5.3 & 5.4 | All flow measuring devices checked & calibrated in accordance with manufacturer's instructions or minimum once yearly? | Yes |
| 5.5 & 5.6 | Quarterly composite sampling for TSS from wastewater settling tank discharge? | Yes. Monthly composite sampling program. |
| OPERATIONS & MAINTENANCE | | |
| 6.1 | All chemicals & materials used in the operation of the drinking water system that come into contact with the water within the system shall meet all applicable standards set by AWWA & ANSI for NSF/60 & NSF/61? | Yes |
| 6.2 | Most current chemical & material product registration documentation from an accredited testing institution shall be available at all times for each chemical & material used in the operation of the drinking water system as per 6.1? | Yes |
| 6.4 | An up to date operations manual shall be maintained & available for reference by all persons responsible for all or part of the operation of the drinking water system? | Yes |
| 6.5 | Operations manual includes requirements of the C of A & associated procedures, operation & recommended maintenance, procedures for monitoring & recording process parameters, procedures for operation & maintenance of monitoring equipment, contingency plans & procedures to deal with emergencies, upset & equipment breakdown, complaint | Yes |



APPENDIX F

| CofA No. | Description | Findings |
|----------|---|--|
| | procedure relating to drinking water system & recording of nature of complaint & follow-up investigation & corrective action. | |
| 6.7 | Up to date process flow diagrams & P & ID diagrams. | Yes |
| 6.8 | As built drawings within one year of facility completion onsite? | Yes for the WTP and Booster station but not the water tower. |
| | | |
| | | |